



**House
Legislative
Analysis
Section**

House Office Building, 9 South
Lansing, Michigan 48909
Phone: 517/373-6466

REQUIRE ILLUMINATED FIRE DOOR HANDLES

House Bill 4069

Sponsor: Rep. Stephen Ehardt

Committee: Regulatory Reform

Complete to 2-15-01

A SUMMARY OF HOUSE BILL 4069 AS INTRODUCED 1-31-01

The bill would amend the Fire Prevention Code to specify that if a fire door is required by law in a building or structure, the fire door would have to have an illuminating door handle assembly connected to a power supply that allows the assembly to emit a light signal in case of a general power failure. The light signal would have to be sufficient to allow a person to locate and determine how to latch and unlatch the fire door.

MCL 29.35

House Bill 4069 (2-15-01)

Analyst: D. Martens

■This analysis was prepared by nonpartisan House staff for use by House members in their deliberations, and does not constitute an official statement of legislative intent.