

**STILLE-DEROSSETT-HALE SINGLE STATE CONSTRUCTION CODE ACT (EXCERPT)**  
**Act 230 of 1972**

**125.1504h Installation of manual fire alarm box required in schools; exception.**

Sec. 4h.

A school building that has a vestibule is not required to have a manual fire alarm box installed within the vestibule if a manual fire alarm box is located within 5 feet of the interior door of the vestibule.

**History:** Add. 2019, Act 20, Eff. Sept. 5, 2019

**Popular Name:** Act 230

**Popular Name:** Uniform Construction Code