

FIRE PREVENTION CODE (EXCERPT)
Act 207 of 1941

***** 29.3d.added THIS ADDED SECTION IS EFFECTIVE SEPTEMBER 5, 2019 *****

29.3d.added Installation of manual fire alarm box required in schools; exception.

Sec. 3d. A school that has a vestibule is not required to install a manual fire alarm box within the vestibule if a manual fire alarm box is located within 5 feet of the interior door of the vestibule.

History: Add. 2019, Act 19, Eff. Sept. 5, 2019.

Compiler's note: Former MCL 29.3d, which pertained to rules relating to moving picture theaters, was repealed by Act 189 of 2006, Imd. Eff. June 19, 2006.